



- NOTES:**
1. WALL THICKNESS & REINFORCEMENT SHOWN SHALL APPLY TO PITS 1200- 2400 DEEP.
  2. ALL REINFORCEMENT LAPS TO BE 300 LONG.
  3. PITS DEEPER THAN 1200 AND LESS THAN 2400 TO BE FITTED WITH STEPIRONS.
  4. PITS MAY REQUIRE HAUCHING DUE TO DEPTH OR TO ACCOMODATE LARGE PIPES.

# CITY OF BALLARAT

No.	AMENDMENTS	DATE

Approved by: \_\_\_\_\_

Date: \_\_\_\_\_

**DOUBLE SIDE ENTRY PIT**  
2100 x 750 WITH GRATED LID



SCALE:  
NOT TO SCALE

SHEET 1 OF 1

DRAWING NO:  
SD-P7